

PUBLIC WORKS DEPARTMENT, HARYANA

O/o Executive Engineer,
Provincial Division No. I, PWD B&R Br., Hisar
Tel. – 01662-239887
Email: pwd-eepl1-hissar@hry.nic.in

To

The Principal,
Govt. Model Sanskriti Sec. School,
Uklana Mandi (1481).

Memo No. 5578 Dated: 17/7/2023

Subject: Regarding issue Safety Certificate of Building.


Reference:- Your office letter No. 2183 dated 13.07.2023.

On the above noted subject, it is submitted that the Sub Divisional Engineer of this office has inspected the School building of Govt. Model Sanskriti Sec. School, Uklana Mandi (1481) in the presence of school authority and reported that as per visual inspection building seems good except Art Block as there are major cracks in the roof of the block but cannot be ascertained as earth quack resistant.

Therefore, as recommended by the Sub Divisional Engineer the building safety certificate is issued for one year N.O.C. from the date of issue of this letter **except Art Block**.

This is for your kind information.

DA/ Nil



Executive Engineer
Provincial Division No. I,
P.W.D. B&R Branch, Hisar

Endst. No.

Dated:

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. I, P.W.D. B&R Branch, Hisar w.r.t. his letter No. 1803 dated 14/07/23 for information.

DA/ Nil


Executive Engineer
Provincial Division No. I,
P.W.D. B&R Branch, Hisar